

Tag Number PR2		Parts to include SS tag with tag name					
Specification							
Fluid: Air		Process Conditions					
Contaminants:							
Temperature: 40F to 125F (or 4.4-52 C)							
Pressure: 300 psig inlet pressure maximum (or 20.6 Bar)							
pH: Neutral							
Pressure Regulator - <u>Standard Air</u> Service , includes gage and T handle, Watts Fluidair model R119G or Equivalent		Typical Selection					
Per the P&ID's or the equipment list. Low = 0-25, Standard = 0-60, High = 0-125.		Reduced pressure range					
Zinc Steel Brass		Body & spring cage Adj. Screw & springs Inner Valve					
Less than or equal to 2 in - FNPT X FNPT Per the P&ID's or the equipment list.		End Connection					
Buna N		Seals					
Notes:		<table border="1"> <tr> <td><u>Rev</u></td> <td><u>Date</u></td> </tr> <tr> <td>0</td> <td>8-Apr-10</td> </tr> </table>		<u>Rev</u>	<u>Date</u>	0	8-Apr-10
<u>Rev</u>	<u>Date</u>						
0	8-Apr-10						
		THIS DRAWING AND ALL INFORMATION THEREON IS THE PROPERTY OF SMI AND IS CONFIDENTIAL. THIS DRAWING AND INCLUDED INFORMATION MUST NOT BE MADE PUBLIC OR COPIED WITHOUT SMI PERMISSION. IT IS SUBJECT TO RETURN ON DEMAND.					
<u>By</u>	<u>Reviewed</u>	<u>Approved</u>	<u>Dwg Number</u>				
JLP			STD-46.1 PR2				
		VALVE TEMPLATE v1 29Jan08.xls					
		Page 1 of 1					



Specialty
MINERALS

Process Engineering
1 Highland Ave. Bethlehem, PA
18017